

Port of Tacoma Request for Proposal # 87000
Addendum #1

Date 7/16/2019

The following is additional information regarding **RFP-87000** titled **Data Center Provider** released on 7/12/2019. **The due date and time for responses remains as 8/2/2019 @ 2:00PM PST.** This addendum includes both questions from prospective bidders and the Port's answers, and revisions to the RFP. This addendum is hereby made part of the RFP and therefore, the information contained herein shall be taken into consideration when preparing and submitting a bid.

Item #	Date Received	Date Answered	Vendor's Question	Port's Answer	RFP Revisions
1	7/15/19	7/16/19	Regarding (RQ1): we do have over 700 feet of space available but since we only allow public entities not Private we do not have the need to have caged environments as we do have a very high security data center.	The ability to have a cage around the space is a mandatory requirement for this procurement.	
2	7/15/19	7/16/19	Regarding (RQ3): Does the fact that the State Data Center in Olympia put us out of the running due to the fact that we are 34 miles away vs the 12 mile limitation stipulated? a. (RQ14): If this requirement has to do with line of site for a wireless connection. Do you have the ability to connect to our data center via another source like Fiber optic connection via Comcast or other carrier?	The distance requirement is related to what we believe would be a reasonable commute/drive time between our offices and the datacenter. This is a high priority (but not mandatory) requirement for this procurement.	
3	7/15/19	7/16/19	Regarding (RQ15 & 16): all our technicians are Bicsi Level 3 Certified technicians. We do not have a need for ITIL certification for the data center. We also have a Bicsi RCDD on staff.	BICSI certification is significant. The ITIL requirements are high priority (but not mandatory) requirements for this procurement.	

Port of Tacoma Request for Proposal # 87000
Addendum #1

Date 7/16/2019

4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					