



SCALE: 3/8"=1'-0"



SCALE: $3/8"=1'-0"$

1. CONTRACTOR SHALL VERIFY DIMENSIONS, ELEVATIONS AND LOCATIONS PRIOR TO CONSTRUCTION.
2. PIPE SUPPORTS NOT SHOWN. PROVIDE PIPE SUPPORTS ON ALL PIPING WHERE NECESSARY.
3. ALL JOINTS AND COUPLINGS SHALL BE RESTRAINED.
4. ALL PIPE PENETRATIONS THROUGH WALLS AND SLABS REQUIRE MODULAR MECHANICAL SEALS WITH TIGHTENING BOLTS INSIDE STRUCTURE. SEE SHEET M10, DETAIL 5.
5. TREMIE MUD SLAB, SEE SPECIFICATIONS FOR MATERIAL AND INSTALLATION REQUIREMENTS. SEE STRUCTURAL SHEETS FOR DETAILS.
6. CSBC, SEE SPECIFICATIONS FOR MATERIAL AND INSTALLATION REQUIREMENTS.
7. INSTALL HARD RUBBER MOUNTS BETWEEN SST GUIDE RAILS AND CONCRETE.
8. BASIS OF DESIGN PUMP REQUIRES A CLEARANCE OF 9 7/8" BETWEEN THE WET WELL FLOOR AND THE PUMP INTAKE. FOR EACH INCH OR FRACTION OF AN INCH OF ADDITIONAL CLEARANCE REQUIRED BY THE PROVIDED PUMP, THE PUMP STATION SYSTEM SUPPLIER SHALL INCREASE THE DEPTH OF THE WET WELL BY AN INCH.
9. BASIS OF DESIGN PUMP REQUIRES A MINIMUM SUBMERGED LEVEL OF 24" TO AVOID DAMAGE TO THE PUMP. FOR EACH INCH OR FRACTION OF AN INCH OF ADDITIONAL SUBMERGENCE REQUIRED BY THE PROVIDED PUMP THE PUMP STATION SYSTEM SUPPLIER SHALL INCREASE THE DEPTH OF THE WET WELL BY AN INCH.
10. SEE SHEET M01 FOR OWNER INSTALLED MATERIAL.
11. INSTALL COLLAR, SEE SHEET C06, DETAIL 2.

THIS DRAWING IS THE PROPERTY OF THE PORT OF LACOMA AND SHALL NOT BE USED ON OTHER WORK, DISCLOSED, COPIED, IN WHOLE OR IN PART, WITHOUT WRITTEN PERMISSION