

Aquatic Propagation Facility at Historic Yates Mill County Park  
Raleigh, North Carolina  
April 21, 2021

ADDENDUM NO. 2  
Page 1

HUFFMAN ARCHITECTS, PA  
632 PERSHING ROAD  
RALEIGH, NORTH CAROLINA 27608  
PHONE (919) 270-6455

TO: ALL PRIME BIDDERS OF RECORD

This Addendum forms a part of the Contract Documents and modifies the original Project Manual and Construction Documents dated March 26, 2021. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification. This addendum consists of one (1) page and no attachments. All documents are distributed digitally.

**DRAWINGS**

Item No.      Description

- 1.      None.

**SPECIFICATIONS**

Item No.      Description

- 1.      None.

**CLARIFICATIONS**

Item No.      Description

- 1.      The new upwellers at the end of the dock shall be provided and installed by the General Contractor.
- 2.      The design team's contact for the special pond water filters and equipment is John Fidgeon, Utility Plant Solutions, Phone 919-801-6452.
- 3.      The existing building controls are by Andover. The Andover system will be replaced by one of the acceptable manufacturers.
- 4.      The existing Fire Alarm service contractor is Schneider.
- 5.      The wood species of the existing wood veneer cabinetry is believed to be red oak. However, there is no past documentation to confirm this or who the manufacturer of the existing cabinetry was. All new wood veneer cabinets and shelving are to be red oak per specification sections 06 4113 Wood Veneer Faced Architectural Cabinets and 12 3200 Manufactured Wood Casework.
- 6.      **An additional walkthrough is scheduled at the Park Center, 4620 Lake Wheeler Road, Raleigh, NC 27603 on Monday, April 26 from 9:00-10:00am. The deadline for questions is Thursday, April 22 at 12:00pm, so no questions will be taken at the walkthrough.**

**END OF ADDENDUM NUMBER TWO**

